



PETRO AZAR ASIA



همکار سازمان ملی استاندارد
بشماره YA/3020

KEROSENE ANALYSIS

ANALYSIS	UNIT	LIMIT	TEST METHOD
Density @15°C	Kg/L	0.798	ASTM D 1298
Distillation	-	-	ASTM D 86
IBP	°C	173	ASTM D 86
10%	°C	183	ASTM D 86
20%	°C	189	ASTM D 86
30%	°C	194	ASTM D 86
40%	°C	199	ASTM D 86
50%	°C	206	ASTM D 86
60%	°C	212	ASTM D 86
70%	°C	220	ASTM D 86
80%	°C	230	ASTM D 86
90%	°C	243	ASTM D 86
95%	°C	257	ASTM D 86
FBP	°C	274	ASTM D 86
Flash point tag	°C	40	ASTM D 93
Corrosion-3 hrs. @100 °c	-	1 a	ASTM D 130
Color	-	0.0	ASTM D 1500
Total sulfur	ppm	1410	ASTM D 4294